



LAKE CITIES FIRE DEPARTMENT



Proudly serving Hickory Creek, Shady Shores, Lake Dallas, and Corinth

David Rodriguez
Interim Fire Marshal

FOOD VENDORS SPECIAL EVENT REQUIREMENTS

1. All **food vendors** will be inspected by the Lake Cities Fire Department for compliance prior to the event.
2. **Non-compliant food vendors or mobile food vehicles will not be allowed to participate for safety reasons.**
3. Cooking under a tents, canopy, or temporary membrane structure, **SHALL** be fire retardant (proof of documentation will be required).
4. All extinguishers must have been serviced by a state-licensed inspector within the last month and year of the event date and have a service tag attached to the fire extinguisher(s).
 - a) General cooking (grills and flat tops) or the use of an open flame equipment (sternos/ chafing fuel), **SHALL** require one (1) 2A10BC (5lb) fire extinguisher.
 - b) If any type of deep frying will be conducted, one (1) 2A10BC (5lb) fire extinguisher **and** one (1) Class K fire extinguisher **SHALL** be required.
5. **Mobile Food Vehicles** (vehicle and enclosed trailers), **SHALL** comply with the current **International Fire Code (IFC)** requirements that have been adopted by Corinth, Lake Dallas, Hickory Creek, and Shady Shores.
 - a) **All mobile food vehicles, cooking or not SHALL have a minimum of one (1) 2A10BC (5lb) fire extinguisher.**
 - b) Cooking equipment that produces grease-laden vapors **SHALL** be provided with a kitchen exhaust hood.
 - c) Cooking equipment **SHALL** be protected by automatic fire extinguisher system. It **SHALL** be maintained and serviced by a state-licensed inspector within the last month and year of the event date and have a service tag attached.
 - d) Portable fire extinguishers **SHALL** be provided with one (1) 2A10BC (5lb) **and** one (1) Class K fire extinguisher. All extinguishers must have been inspected and serviced by a state-licensed inspector within the last month and year of the event date and have a service tag attached to the fire extinguisher(s).

Note: If the fire extinguisher is purchased new, a copy of the receipt shall be attached to the cylinder body of the extinguisher.

COOKING & NON-COOKING VENDORS SPECIAL EVENT REQUIREMENTS

1. Canopies, tents, and other membrane structures shall be properly anchored and braced to withstand the weather and to protect against collapse.
2. Open flame or other devices emitting flame, fire, or heat or any flammable or combustible liquids, gas, charcoal or other cooking device or any other unapproved devices shall not be permitted inside or located within 10-feet of the tent or membrane structures while open to the public unless approved by the fire code official.
3. All power cables/cords (extension cords) shall be in good operating condition. No splicing, taped, or damaged power cables/cords shall be allowed.
4. The use of any fuel powered equipment (generators) shall require a minimum of one (1) 2A10BC (5lb) fire extinguisher.
5. All generators shall be secured away and not accessible to the public (Fencing may be required if safety cannot be met).
6. Portable generators shall be located a minimum 10-feet away from canopies, tent, bounce houses, or like structure.
7. Additional fuel sources shall be stored away from all generators a minimum of 10-feet away and away from the public (Gas Cans, Propane, LP gas).



David Rodriguez
Interim Fire Marshal
Lake Cities Fire Department